

TEST REPORT

Applicant

: StaticTech

Address

: 6200 Bury Drive, Eden Prairie, MN 55346, USA

Report on the submitted sample said to be:

Sample Name

: ESD Rubber Mat

Description

: Normal

Model/type

: SP2051, SP2052, SP2053, SP2054, SP2055 SP2056. SP2057, SP2058, SP2059

Manufacturer

: Static Tech

Address

: 6200 Bury Drive, Eden Prairie, MN 55346, USA

Received Date

: Jul.09, 2017

tested Date

: Jul.09, 2017 - Jul.14, 2017

Test Requested

Test result

IEC 61340-4-1:2015

Electrostatics - Part 4-1: Standard test methods for specific applications -

Pass

Electrical resistance of floor coverings and installed floors

Prepared by:

Examine By:

Eva

Calvin Chen

Calvin Chen

Vachael Mo

- Table 1

pproved (Manager):

H Building, Hongfa Science and Technology Park, Tangtou, Shiyan, Bao'an District, Shenzhen, Guangdong, China Web: http://www.poce-cert.com Tel: 86-755-29113252 E-mail: service@poce-cert.com



	IEC 61340-4-1:2015	T	
Clause	Requirement - Test	Result - Remark	Verdict
5	Apparatus		Р
5.1	Resistance measuring apparatus		Р
	This apparatus consists of a self-contained resistance		Р
	meter (ohmmeter) or power supply and current meter		
	in the appropriate configuration for resistance		
	measurement, with a ±10 % accuracy, and capable of		
	the following requirements.		
5.1.1	Laboratory evaluations		Р
	The apparatus shall have a circuit voltage while under		Р
	load of		
	$-$ 10 V \pm 0,5 V for resistance below 1,0 \times 106 Ω		
	– 100 V \pm 5 V for resistance between 1,0 × 106 Ω and		
	1,0 × 1011 Ω		
	$-$ 500 V \pm 25 V for resistance above 1,0 × 1011 Ω		
5.1.2	Acceptance testing		Р
	A laboratory evaluation apparatus shall be used for		Р
	acceptance testing or an apparatus with an		
	open-circuit voltage of		
	$-$ 10 V \pm 0,5 V for resistance below 1,0 \times 106 Ω		
	– 100 V \pm 5 V for resistance between 1,0 × 106 Ω and		
	1,0 × 1011 Ω		
	$-500 \text{ V} \pm 25 \text{ V}$ for resistance above 1,0 × 1011 Ω .		
5.2	Measuring electrodes		Р
	a)2,5 kg ± 0,25 kg for measurements on hard,		Р
	non-conformable surfaces; or		
	b)5,0 kg ± 0,25 kg for measurements on all other		Р
	surfaces.		
5.3	Counter-electrode		Р
	The counter-electrode consists of a flat stainless steel		Р
	plate, 600 mm ± 10 mm square and of 1 mm		
	(nominal) thickness, with a terminal for connection to		
	the resistance measuring apparatus.		
5.4	Support plates		Р
	For point-to-point resistance measurements, where		Р
	required (see Clause 6) and resistance to ground		
	measurements: support plates shall be equal in area		
	to the test specimens, of sufficient rigidity to hold		
	specimens together for testing, and made from		
	insulating material with a vertical resistance at least		
	one order of magnitude greater than the expected		



Olassa	IEC 61340-4-1:2015	<u> </u>	
Clause	Requirement - Test	Result - Remark	Verdic
	value or if the expected value is unknown, greater		
	than 1014 Ω.		
5.5	Insulating plate		Р
	For vertical resistance measurements: a flat plate 640		Р
	mm ± 10 mm square, 5 mm ± 1 mm thick, made from		
	insulating material with a vertical resistance greater		
	than 1014 Ω shall be used. For point-to-point and		
	resistance to ground measurements: a flat plate 1 300		
	mm ± 10 mm by 600 mm ± 10 mm, 5 mm ± 1 mm		
	thick, made from insulating material with a vertical		
	resistance at least one order of magnitude greater		
	than the expected value or if the expected value is		
	unknown, greater than 1014 Ω shall be used.		
6	Sampling for laboratory evaluations		Р
	Selection and sampling of test materials shall be		Р
	carried out according to ISO 1957. Although ISO		
	1957 is intended for textile floor coverings, its		
	principles are relevant to other types of floor covering.		
7	Preparation of test specimens		Р
	If considered necessary, specimens shall be cleaned		Р
	before conditioning and testing.		
	Cleaning shall be carried out according to the		
	manufacturer's instructions or as otherwise agreed.		
8	Atmosphere for conditioning and testing		Р
	Unless otherwise agreed or specified, the		Р
	atmosphere for conditioning and testing shall be 23		
	°C ± 2 °C and 12 % ± 3 % relative humidity. The		
	conditioning time prior to testing shall be at least 48 h.		
	Textile floor coverings are preferably pre-conditioned		
	for at least 24 h at 20 °C ± 2 °C and 65 % ± 3 %		
	relative humidity prior to conditioning and testing.		
9	Test procedures		Р
9.1	Cleaning electrodes		Р
	Prior to each test sequence, clean the contact area of		Р
	the measuring and counter-electrodes using a		
	low-linting cloth moistened with either ethanol or		
	propan-2-ol (≥95 % concentration). Allow the surfaces		
	to dry before making measurements		
9.2	Point-to-point resistance		Р
	a) the measured resistance at 10 V is greater than 1,0		Р
	\times 106 Ω and the measured resistance at 100 V is less		



Clause	Deguirement Test	Result - Remark	Verdict
	Requirement - Test	Result - Remark	verdict
	than 1,0 × 106 Ω; or		
	b) the measured resistance at 100 V is greater than		
	$1.0 \times 1011 \Omega$ and the measured resistance at 500 V is		
	less than 1,0 × 1011 Ω.		
9.3	Vertical resistance (laboratory evaluations only)		P
	a) the measured resistance at 10 V is greater than 1,0		Р
	\times 106 Ω and the measured resistance at 100 V is less		
	than 1,0 × 106 Ω; or		
	b) the measured resistance at 100 V is greater than		
	$1.0 \times 1011~\Omega$ and the measured resistance at 500 V is		
	less than 1,0 × 1011 Ω.		
9.4	Resistance to ground		Р
	a) the measured resistance at 10 V is greater than 1,0		Р
	\times 106 Ω and the measured resistance at 100 V is less		
	than 1,0 × 106 Ω; or		
	b) the measured resistance at 100 V is greater than		
	$1.0 \times 1011~\Omega$ and the measured resistance at 500 V is		
	less than 1,0 × 1011 Ω.		
10	Calculation and expression of results		Р
	For each sample and each type of measurement,		Р
	calculate the geometric mean of the individual		
	readings. Express both the individual results and the		
	geometric means to two significant figures.		
11	Test report		Р
	The test report shall include at least the following		Р
	information:		
	a) reference to this International Standard, i.e. IEC		Р
	61340-4-1;		
	b) all the information necessary for complete		Р
	identification of test samples;		
	c) date of testing;	Jul.15, 2017-	Р
	d) the atmosphere for pre-conditioning, conditioning	25℃	Р
	and testing as follows:	52% RH	
	– for laboratory evaluations: temperature and relative	0276141	
	humidity during pre-conditioning (if used),		
	conditioning and testing, and the duration of any		
	pre-conditioning and conditioning;		
	– for tests on installed floors: temperature and relative		
	humidity during testing;		
	e) details of any cleaning or finishing procedures;		P
	f) details of any procedures used to combine small		<u>'</u> Р



	IEC 61340-4-1:2015		
Clause	Requirement - Test	Result - Remark	Verdict
	specimens together;		
	g) details of any support plates used and procedures		Р
	and materials used to fix samples to support plates;		
	h) details of any procedures and materials used to fix		Р
	groundable point(s) to samples;		
	i) type of measurement: point-to-point resistance,		Р
	vertical resistance, resistance to ground;		
	j) the circuit voltage under load used when making		Р
	measurements;		
	k) all individual results for each type of measurement		Р
	on each specimen;		
	I) the geometric mean of all results for each type of		Р
	measurement on each sample;		
	m) any opera+tions not specified in this part of IEC		Р
	61340, or in any standard to which normative		
	reference is made, or regarded as optional, which		
	might have affected the results.		



TEST RESULTS

Resistance meter set to apply 100V for 15 seconds; test atmosphere 23 °C, 25% relative humidity

Test Area	Surface Resistance /	Surface Resistivity /
Surface Resistivity /		
top surface		
1	20.5 x 10 ⁶	4.06 x 10 ⁸
2	9.7×10^6	1.92 x 10 ⁸
3	6.1 x 10 ⁶	1.21 x 10 ⁸
4	3.58 x 10 ⁶	7.09 x 10 ⁷
5	25.3 x 10 ⁶	5.01 x 10 ⁸
Outer surface mean	Mean = 1.30 x 10 ⁷	Mean = 2.57 x 10 ⁸
bottom surface		
1	1.92 x 10 ⁴	3.80×10^5
2	2.53 x 10 ⁴	5.01 x 10 ⁵
3	2.71 x 10 ⁴	5.37 x 10 ⁵
4	2.02 x 10 ⁴	4.00 x 10 ⁵
5	2.23 x 10 ⁴	4.42 x 10 ⁵
Inner surface mean	Mean = 2.28 x 10 ⁴	Mean = 4.52 x 10 ⁵

- 1. Mean values are the geometrical mean, not the arithmetic mean
- 2. Surface resistivity is derived by multiplying the surface resistance by a form factor related to the dimensions of the electrodes. The form factor for the electrodes in use at SATRA is 19.8



PHOTOS

Photo 1 view Ifront back side top internal bottom	5 6 7 8 9 19 11 12 19 14 15 16 17 18 19 20 21 22 23 24 25 16 27 25 29 30 33 33 33 33
Photo 2 view front back side top internal bottom	90名

***** THE END *****